

Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)  
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE

The COMANCHE COUNTY WSC SIPE SPRINGS water system PWS ID 0470027 has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of the monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring period of the fourth quarter of 2025.

We are taking the following actions to address this issue: We are making sure the DLQOR has been submitted to TCEQ a week before the due date.

Please share this information with all people who drink this water, especially those who may not have received a notice directly (i.e., people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, you may contact Emily Moreno at (254) 893-3678.

Posted/Delivered on: April 24, 2026